

1810 Heavy-Duty Modular Single Cartridge Seal

Installation, Operation and Rebuild Instructions




TABLE OF CONTENTS

1.0 Cautions	2
1.1 General	2
1.2 Label Warnings	2
2.0 Transport and Storage	2
3.0 Description	2
3.1 Parts Identification	2 – 3
3.2 Operating Parameters	4
3.3 Intended Use	4
3.4 Dimensional Data	4 – 9
4.0 Preparation for Installation	10
4.1 Equipment	10
4.2 Mechanical Seal	11
5.0 Seal Installation	12
6.0 Commissioning/Equipment Start-up	13
7.0 Decommissioning/Equipment Shut Down	14
8.0 Spare Parts	14
9.0 Seal Rebuild	15
9.1 Seal Rebuild	15
9.1.1 Seal Disassembly	15 – 16
9.1.2 Seal Assembly	17 – 19
10.0 Mechanical Seal Returns and Hazard Communication Requirements	20

Seal Data Reference

(from Box Label)

ITEM # _____

SEAL _____

(Example: 1810 1.875 SA CB/SSC S FKM)

INSTALLATION DATE _____

1.0 CAUTIONS

1.1 General

These instructions are general in nature. It is assumed that the installer is familiar with seals and certainly with the requirements of their plant for the successful use of mechanical seals. If in doubt, seek assistance from someone in the plant who is familiar with seals or delay the installation until a seal representative is available. All necessary auxiliary arrangements for successful operation (heating, cooling, flushing) as well as safety devices must be employed. These decisions are to be made by the user. The decision to use this

seal or any other Chesterton seal in a particular service is the customer's responsibility.

Do not touch the mechanical seal for any reason while it is operating. Lockout or uncouple the driver prior to personal contact with the seal. Do not touch the mechanical seal while it is in contact with hot or cold fluids. Ensure that all the mechanical seal materials are compatible with the process fluid. This will prevent possible personal injury.

1.2 Label Warnings

635 SXC Synthetic, Extreme Pressure, Corrosion Resistant Grease. Chesterton International GmbH, Am Lenzenfleck 23, D85737, Ismaning, Germany – Tel. +49-89-996-5460.

Contains Benzenesulfonic acid, C10-16-alkyl derivs., calcium salts, Sulfonic acids, petroleum, calcium salts and Benzenesulfonic acid, mono-C16-24-alkyl derivs., calcium salts. May produce an allergic reaction. Safety Data Sheet available on request.

2.0 TRANSPORT AND STORAGE


Transport and store seals in their original packaging. Mechanical seals contain components that may be subject to alteration and aging. It is therefore important to observe the following conditions for storage:

- Dust free environment
- Moderately ventilated at room temperature
- Avoid exposure to direct sunlight and heat
- For elastomers, storage conditions according to ISO 2230 should be observed.

3.0 DESCRIPTION

3.1.1 1810 Parts Identification

Figure 1




KEY

- 1 – Sleeve Assembly
- 2 – Shaft O-Ring (V)
- 3 – Rotary Cushion
- 4 – Rotary O-Ring (W)
- 5 – Gland
- 6 – Rotary Seal Ring
- 7 – Gasket
- 8 – Injector (Optional)
- 9 – Stationary Seal Ring
- 10 – Stationary O-Ring (X)
- 11 – Follower Assembly
- 12 – Lock Ring
- 13 – 1/4 Dog Set Screw
- 14 – Cup Point Set Screw (not shown)
- 15 – Bushing (Optional)
- 16 – Bushing O-Ring (Optional) (Y)
- 17 – Snap Ring (Optional)
- 18 – Centering Clip
- 19 – Flat Head Screw
- 20 – Spring
- 21 – Stationary Cushion
- 22 – Pipe Plug
- 23 – Drive Tube

3.1.2 1810T Parts Identification

Figure 2



KEY

- 1 – Sleeve Assembly
- 2 – Shaft O-Ring (V)
- 3 – Rotary Cushion
- 4 – Rotary O-Ring (W)
- 5 – Gland
- 6 – Rotary Seal Ring
- 7 – Gasket
- 8 – Injector (Optional)
- 9 – Stationary Seal Ring
- 10 – Stationary O-Ring (X)
- 11 – Follower Assembly
- 12 – Lock Ring
- 13 – 1/4 Dog Set Screw
- 14 – Cup Point Set Screw (not shown)
- 15 – Bushing (Optional)
- 16 – Bushing O-Ring (Optional) (Y)
- 17 – Snap Ring (Optional)
- 18 – Centering Clip
- 19 – Flat Head Screw
- 20 – Spring
- 21 – Stationary Cushion
- 22 – Pipe Plug
- 23 – Drive Tube

3.0 DESCRIPTION cont.

3.2 Operating Parameters*

Pressure Limits:

1810 Seals can withstand operating pressures from vacuum (710 mm or 28" Hg) to the maximum pressures.

25 mm – 120 mm (1.000" – 4.750") up to 40 barg (600 psig)

Standard Materials:**All Metal Parts:**

316 Stainless Steel/EN 1.4401

Bronze

Springs: Alloy C-276/EN 2.4819

Rotary Face: CB; SSC; TC

Stationary Face: SSC; TC

Elastomers*: FKM, EPDM, FEPM, or FFKM

**Other materials available upon request.*

Speed Limits:

25 mm – 120 mm (1.000" – 4.750") up to 25 mps (5000 FPM)

Temperature Limits:

Elastomers

To 150°C (300°F) EPDM

To 205°C (400°F) FEPM, FKM

To 260°C (500°F) FFKM

**Environmental controls may be required for the specific application.*

Limits can change depending on operating conditions, size and seal ring material.


Consult Chesterton Mechanical Seal Application Engineering for operating conditions outside of these published parameters.

3.3 Intended Use

The mechanical seal is to be operated within the operating parameters as specified. For use beyond the intended application and/or outside the operating parameters, consult Chesterton Mechanical Seal Application Engineering to confirm the suitability of the mechanical seal prior to putting the mechanical seal in operation.


3.4.1 1810 Dimensional Data (Drawings)

Figure 3



3.4.2 1810T Dimensional Data (Drawings)

Figure 4



3.0 DESCRIPTION cont.

3.4.3 1810 Dimensional Data

METRIC - Millimeters

SHAFT SIZE	GLAND OD	STUFFING BOX BORE		IB SEAL DIA	SB DEPTH	OB LENGTH	BOLT CIRCLE BY BOLT SIZE				STUFFING BOX TO BOLT SURFACE	NPT SIZE
		C MIN	C MAX				G MIN					
A	B MAX	C MIN	C MAX	D MAX	E MIN	F MAX	10 mm	12 mm	16 mm	20 mm	J MAX	P
25	104,0	44,2	51,0	43,0	18,5	49,5	72,7	–	–	–	43,0	1/4 – 18
28	104,0	47,2	51,0	46,2	18,5	49,5	72,7	–	–	–	43,0	1/4 – 18
30	104,0	49,3	56,0	47,6	18,5	49,5	77,6	–	–	–	43,0	1/4 – 18
30 OS	126,6	59,4	68,1	47,4	18,5	49,5	90,0	–	–	–	32,3	1/4 – 18
32	110,7	51,1	57,0	50,6	18,5	49,5	79,7	–	–	–	43,0	1/4 – 18
33	110,7	52,1	58,0	50,6	18,5	49,5	79,2	81,2	–	–	43,0	1/4 – 18
35	110,7	54,1	59,0	52,5	18,5	49,5	82,9	84,9	–	–	43,0	1/4 – 18
38	113,9	57,2	66,0	55,7	18,5	49,5	86,3	88,3	–	–	43,0	3/8 – 18
40	126,6	59,2	68,0	57,6	18,5	49,5	88,1	90,1	–	–	43,0	3/8 – 18
40 OS	126,6	69,1	74,2	57,6	18,5	49,5	96,5	–	–	–	32,3	3/8 – 18
42	126,6	61,2	68,0	59,6	18,5	49,5	88,6	90,6	–	–	43,0	3/8 – 18
43	126,6	62,2	68,0	60,6	18,5	49,5	93,7	95,7	–	–	43,0	3/8 – 18
45	139,0	64,3	73,0	62,6	18,5	49,5	93,1	95,1	–	–	43,0	3/8 – 18
48	139,0	67,1	73,0	65,6	18,5	49,5	93,5	95,5	–	–	43,0	3/8 – 18
50	139,0	69,1	78,0	67,6	18,5	49,5	98,2	100,2	–	–	43,0	3/8 – 18
50 OS	152,0	84,9	96,3	67,6	18,5	49,5	118,6	120,6	–	–	32,3	3/8 – 18
53	152,0	72,1	87,0	71,6	18,5	49,5	108,0	110,0	114,0	–	43,0	3/8 – 18
55	152,0	74,2	83,0	72,6	18,5	49,5	104,2	106,2	110,2	–	43,0	3/8 – 18
58	152,0	77,2	91,0	77,9	18,5	49,5	115,9	117,9	121,9	–	43,0	3/8 – 18
60	152,0	79,2	91,0	77,9	18,5	49,5	115,9	117,9	121,9	–	43,0	3/8 – 18
60 OS	164,7	96,1	107,4	77,9	18,5	49,5	129,8	131,8	–	–	32,3	3/8 – 18
65	163,8	84,1	100,0	84,3	18,5	49,5	127,1	129,1	133,1	–	43,0	3/8 – 18
70	196,0	95,5	111,3	93,2	24,4	63,0	–	137,0	141,1	–	45,0	1/2 – 14
75	202,0	101,6	119,1	99,4	24,4	63,0	–	142,8	146,9	–	45,0	1/2 – 14
80	203,0	106,0	122,2	103,3	24,4	63,0	–	150,2	154,3	–	45,0	1/2 – 14
85	211,0	111,3	128,0	109,0	24,4	63,0	–	156,5	160,7	165,0	45,0	1/2 – 14
90	215,0	115,6	131,8	113,2	24,4	63,0	–	159,6	163,7	167,6	45,0	1/2 – 14
95	222,0	120,7	136,9	118,5	24,4	63,0	–	161,4	165,5	170,0	45,0	1/2 – 14
100	228,0	127,0	144,0	124,8	24,4	63,0	–	168,5	172,3	177,0	45,0	1/2 – 14
110	238,0	136,7	154,0	134,4	24,4	63,0	–	177,9	181,7	185,9	45,0	1/2 – 14
120	267,0	146,1	164,3	143,9	24,4	63,0	–	191,3	195,2	199,3	45,0	1/2 – 14

3.0 DESCRIPTION cont.

3.4.4 1810 Dimensional Data

INCH

SHAFT SIZE	GLAND OD	STUFFING BOX BORE		IB SEAL DIA	SB DEPTH	OB LENGTH	BOLT CIRCLE BY BOLT SIZE				STUFFING BOX TO BOLT SURFACE	NPT SIZE
A	B MAX	C MIN	C MAX	D MAX	E MIN	F MAX	G MIN				J MAX	P
							3/8"	1/2"	5/8"	3/4"		
1.000	4.09	1.75	2.01	1.69	0.73	1.95	2.87	—	—	—	1.27	1/4 – 18
1.125	4.09	1.88	2.04	1.82	0.73	1.95	2.87	—	—	—	1.27	1/4 – 18
1.125 OS	4.49	2.24	2.79	1.81	0.73	1.95	3.65	—	—	—	1.27	1/4 – 18
1.250	4.09	2.00	2.27	1.94	0.73	1.95	3.14	—	—	—	1.27	1/4 – 18
1.375	4.36	2.13	2.33	2.07	0.73	1.95	3.26	3.38	—	—	1.27	1/4 – 18
1.375 OS	5.39	2.72	2.92	2.06	0.73	1.95	3.78	—	—	—	1.27	1/4 – 18
1.500	4.49	2.25	2.63	2.19	0.73	1.95	3.39	3.52	—	—	1.27	3/8 – 18
1.625	4.99	2.38	2.69	2.32	0.73	1.95	3.50	3.63	—	—	1.27	3/8 – 18
1.750	5.47	2.50	2.81	2.44	0.73	1.95	3.62	3.74	—	—	1.27	3/8 – 18
1.750 OS	6.65	3.20	3.73	2.44	0.73	1.95	4.59	4.72	—	—	1.27	3/8 – 18
1.875	5.47	2.63	2.94	2.57	0.73	1.95	3.74	3.87	—	—	1.27	3/8 – 18
1.875 OS	5.99	3.41	3.79	2.57	0.73	1.95	4.65	4.78	—	—	1.27	3/8 – 18
2.000	5.47	2.75	3.19	2.69	0.73	1.95	4.13	4.25	—	—	1.27	3/8 – 18
2.125	5.99	2.88	3.44	2.82	0.73	1.95	4.25	4.37	4.50	—	1.27	3/8 – 18
2.125 OS	6.99	3.70	4.23	2.82	0.73	1.95	5.09	5.22	5.34	—	1.27	3/8 – 18
2.250	5.99	3.00	3.56	2.94	0.73	1.95	4.37	4.49	4.62	—	1.27	3/8 – 18
2.375	5.99	3.13	3.59	3.07	0.73	1.95	4.56	4.68	4.81	—	1.27	3/8 – 18
2.375 OS	8.39	3.93	4.48	3.07	0.73	1.95	5.34	5.47	5.59	—	1.27	3/8 – 18
2.500	6.45	3.25	3.81	3.19	0.73	1.95	4.62	4.74	4.87	—	1.27	3/8 – 18
2.500 OS	7.76	3.93	5.23	3.19	0.73	1.95	6.09	6.22	6.34	—	1.27	3/8 – 18
2.625	6.45	3.38	3.94	3.32	0.73	1.95	5.00	5.12	5.25	—	1.27	3/8 – 18
2.625 OS	6.98	4.30	4.76	3.32	0.73	1.95	5.62	5.75	5.87	—	1.27	3/8 – 18
2.750	7.71	3.75	4.38	3.67	0.96	2.48	—	5.42	5.55	—	1.77	1/2 – 14
2.750 OS	7.89	4.45	4.76	3.67	0.94	2.48	—	5.75	5.87	6.00	1.63	1/2 – 14
2.875	7.83	3.88	4.50	3.79	0.96	2.48	—	5.61	5.74	—	1.77	1/2 – 14
3.000	7.94	4.00	4.69	3.92	0.96	2.48	—	5.65	5.78	—	1.77	1/2 – 14
3.000 OS	8.64	4.92	5.37	3.91	0.94	2.48	—	6.36	6.48	6.61	1.63	1/2 – 14
3.125	7.99	4.13	4.81	4.04	0.96	2.48	—	5.80	5.93	—	1.77	1/2 – 14
3.250	8.19	4.25	4.94	4.17	0.96	2.48	—	6.07	6.20	—	1.77	1/2 – 14
3.375	8.31	4.38	5.06	4.29	0.96	2.48	—	6.19	6.32	6.44	1.77	1/2 – 14
3.375 OS	8.39	5.00	5.26	4.29	0.94	2.48	—	6.23	6.35	6.48	1.63	1/2 – 14
3.500	8.44	4.50	5.19	4.42	0.96	2.48	—	6.18	6.31	6.43	1.77	1/2 – 14
3.625	8.49	4.63	5.31	4.54	0.96	2.48	—	6.42	6.55	6.67	1.77	1/2 – 14
3.750	8.72	4.75	5.39	4.67	0.96	2.48	—	6.38	6.51	6.63	1.77	1/2 – 14
3.750 OS	9.76	5.95	6.38	4.66	0.94	2.48	—	7.37	7.49	—	1.63	1/2 – 14
3.875	8.84	4.88	5.51	4.79	0.96	2.48	—	6.62	6.75	6.87	1.77	1/2 – 14
4.000	8.96	5.00	5.69	4.92	0.96	2.48	—	6.66	6.78	6.91	1.77	1/2 – 14
4.125	8.99	5.13	5.81	5.04	0.96	2.48	—	6.78	6.90	7.03	1.77	1/2 – 14
4.125 OS	9.76	5.96	6.26	5.04	0.94	2.48	—	7.23	7.35	7.48	1.63	1/2 – 14
4.250	8.99	5.25	5.94	5.17	0.96	2.48	—	7.07	7.19	7.32	1.77	1/2 – 14
4.375	9.34	5.38	6.06	5.29	0.96	2.48	—	7.03	7.15	7.28	1.77	1/2 – 14
4.500	9.49	5.50	6.19	5.42	0.96	2.48	—	7.18	7.30	7.43	1.77	1/2 – 14
4.500 OS	12.49	6.74	7.49	5.41	0.94	2.48	—	8.46	8.58	8.71	1.63	1/2 – 14
4.625	9.49	5.63	6.31	5.54	0.96	2.48	—	7.45	7.58	7.70	1.77	1/2 – 14
4.750	10.49	5.75	6.47	5.67	0.96	2.48	—	7.56	7.68	7.81	1.77	1/2 – 14
4.750 OS	11.39	7.20	7.63	5.66	0.94	2.48	—	8.62	8.74	8.87	1.63	1/2 – 14

3.0 DESCRIPTION cont.


3.4.5 1810T Dimensional Data

INCH


SHAFT SIZE	GLAND OD	STUFFING BOX BORE		IB SEAL DIA	SB DEPTH	OB LENGTH	BOLT CIRCLE BY BOLT SIZE				STUFFING BOX TO BOLT SURFACE	NPT SIZE
A	B MAX	C MIN	C MAX	D MAX	E MIN	F MAX	G MIN				J MAX	P
1.125	4.08	1.75	2.04	1.69	0.54	2.13	3/8"	1/2"	5/8"	3/4"	1.22	1/4 – 18
1.375	4.35	2.00	2.33	1.94	0.54	2.13	3.25	3.39	–	–	1.22	1/4 – 18

4.0 PREPARATION FOR INSTALLATION

4.1 Equipment




If practical, place the dial indicator tip on the end of the shaft sleeve or on a step in the shaft to measure end play. Alternately push and pull the shaft in the axial direction. If the bearings are in good condition, end play should not exceed 0,13 mm (.005").




If possible, attach a base dial indicator to the shaft and rotate both the indicator and shaft slowly while reading the runout of the stuffing box face. Misalignment of the stuffing box face relative to the shaft should not exceed 0,005 mm TIR per mm (.005 in per inch) of shaft diameter.

The stuffing box face must be flat and smooth enough to seal the gland. Surface roughness should be 3,2 microns (125 microinch) Ra maximum for gaskets and 1,1 micron (45 microinch) Ra for O-Rings. Steps between halves of split case pumps should be machined flat. Make sure the stuffing box is clean and clear along its entire length.



Remove all sharp corners, burrs, and scratches on the shaft, especially in areas where the O-Ring will slide, and polish if necessary to achieve a 0,8 micron (32 microinch) Ra finish. Make sure the shaft or sleeve diameter is within 0,05 mm (.002") of nominal.



Use a dial indicator to measure the shaft runout in the area where the seal will be installed. Runout should not exceed 0,001 mm TIR per mm (.001 in per inch) of shaft diameter.


4.2 Mechanical Seal

1. Check to ensure that the O-Rings installed in this seal are compatible with the fluid being sealed.
2. The 1/4 dog set screws go into the smaller holes in the sleeve. The dimples on the outside diameter of the lock ring indicate the position of the 1/4 dog set screws. Do not disengage these screws from the sleeve when positioning the seal. The cup point set screws go through the larger holes in the sleeve. Make sure all screws are engaged in the sleeve but do not protrude into the inside diameter bore. Also, when repositioning or removing the seal, make sure the centering clips and flat head screws are engaged.
3. Centering clips have been preset at the factory. If for any reason you loosen or remove the centering clip flat head screws, retighten as follows prior to installing the seal on the equipment: Tighten the flat head screw finger tight, ensuring the centering clips are properly engaged. Then using a hex key, tighten flat head screw an additional 1/8 turn. This will approximate the 4,5 Nm (40 inch-pounds) of torque for sizes 25 mm – 65 mm (1.000" – 2.650"), 7,8 Nm (70 inch-pounds) of torque for 70 mm – 120 mm (2.750" – 4.750") set at the factory.
4. **IMPORTANT:** When seal is purchased without the bushing option the quench and drain ports will be plugged. **DO NOT** remove these plugs or attempt to use the quench/drain environmental controls without the bushing option.
5. With Injector option (distributed flush) seals require environmental controls (API Plan 11 or equivalent) connected to "F" port.

5.0 SEAL INSTALLATION




Tools required for installation: Hex key and white grease (**supplied with seal**); open end or socket wrench (size dependent on mounting bolt size; **supplied by customer**). **IMPORTANT: Seal data can be accessed from the installed RFID tag; you may also choose to fill in seal data reference from the box label on the cover page of these instructions.**




Apply a thin film of **white** grease to the shaft/O-Ring (V) and slide seal onto the shaft by pushing on the gland. **CAUTION: Ensure that all set screws are engaged through the sleeve but do not protrude into the sleeve inside diameter bore.**




Reassemble the pump and make necessary shaft alignments and impeller adjustments. The impeller can be reset at any time, as long as the centering clips are in place and the seal set screws are loosened while the shaft is being moved. (see Figures 4 and 5) for port orientation. **CAUTION: See (4.2.3 Preparation for Installation – Mechanical Seal step 3.)**



Tighten the gland bolts evenly. **IMPORTANT: The gland bolts must be tightened before tightening the set screws onto the shaft. Gland bolt torque is dependent on application. IMPORTANT: Piping connections should not be made prior to tightening the gland bolts.**



IMPORTANT: 1/4 dog set screws (1) must be tightened FIRST and cup point set screws (2) must be tightened last. 1/4 dog set screw locations are marked with a dimple on the outside diameter of the lock ring, next to the screw holes.




Tighten three 1/4 dog set screws (1) (see inset image, marked with a dimple) evenly with the hex key provided.



Tighten cup point set screws (2) evenly with the hex key provided. **IMPORTANT: After all sets screws have been tightened by hand, retighten with a torque wrench:**
Sizes 25 mm – 65 mm (1.000" – 2.625") to 5,5 – 6,5 Nm (50 – 60 in-lbs.)
Sizes 70 mm – 120 mm (2.750" – 4.750") to 12 – 13 Nm (105 – 115 in-lbs.)



Remove all flat head screws and centering clips and retain for future use when making impeller adjustments and/or seal removal.



IMPORTANT: To ensure that the gland is properly centered over the sleeve turn the shaft by hand and make sure the seal turns freely. If you hear/feel metal to metal contact within the seal, it was improperly centered. Re-install the centering clips finger tight. Remove any piping connections. Loosen the gland bolts. Fully tighten clips. Loosen the set screws. Re-tighten the gland bolts. Re-tighten the set screws. Remove the clips. If metal to metal contact still exists check the centering of the stuffing box.

6.1 Attach appropriate environmental controls to the seal. (see Figure 5 and 6)

6.2 Take all necessary precautions and follow normal safety procedures before starting the equipment

**Please contact Chesterton Mechanical Seal Application Engineering for assistance regarding cartridge seals.*

Figure 5
No Bushing Option
Preferred Orientation for **Flush Only**
Port "F" Connect Here





Figure 6
Bushing Option Included
Preferred Orientation for Quench/Drain and Flush
Quench "Q/D" Port Only



7.0 DECOMMISSIONING / EQUIPMENT SHUT DOWN

Ensure that the equipment is electrically isolated. If the equipment has been used on toxic or hazardous fluids, ensure that the equipment is correctly decontaminated and made safe prior to commencing work. Ensure that the pump is isolated and check that the stuffing box is drained from any fluid and

pressure is fully released. **IMPORTANT: Replace centering clips prior to seal removal from equipment!** Remove the seal from equipment in the reverse order from installation instructions. In case of disposal, ensure the local regulations and requirements for disposal or recycling of the different components in the seal are adhered to.

8.0 SPARE PARTS

Use only Chesterton original spare parts. Use of non-original spare parts represents risk of failure, danger to persons/ equipment and voids the product warranty.

Spare Parts Kit can be purchased from Chesterton, referencing the (as manufactured) seal data from the installed RFID tag or from recorded data on the cover page of these instructions.


9.0 SEAL REBUILD

9.1 Seal Rebuild


A correctly installed and operated mechanical seal requires little maintenance. It is recommended to periodically check the seal for leakage. Some components of a mechanical seal such as seal faces, O-Rings, etc., require replacement over time. While a seal is installed and operating, maintenance is not possible. Therefore it is recommended that a spare seal unit or a spare parts / bushing kit be held in stock to allow quick repair.

1. Note the condition of the parts, including elastomer surfaces and gland springs. Analyze the cause of failure and correct the problem, if possible, before reinstalling the seal.
2. Clean all elastomer and gasket surfaces with an approved cleaning solvent that complies with local and site regulations.


9.1.1 Seal Disassembly




Tools required for disassembly of seal: Hex key (supplied with seal); tweezers and a curved pick (supplied by customer; for removal of O-Rings and drive tube).




Remove the centering clips and discard.




Remove all cup point and 1/4 dog set screws from the lock ring and discard.




Remove the lock ring from sleeve and set aside.



Separate the sleeve from the gland and set the sleeve aside.




Remove the stationary seal ring from the gland and discard.



Remove the O-Ring (X) from the gland O-Ring groove and discard.




Remove the follower assembly from the gland and set it aside.




Remove all springs from the gland spring holes and discard.


9.1.1 Seal Disassembly cont.




For seals with Injector option: Carefully remove the injector, and set it aside.




For seals with Bushing kit: Remove the snap ring from the gland and discard.




For seals with Bushing kit: Remove the bushing and bushing O-Ring (Y) from the gland bore and discard.




Remove the stuffing box face gasket from the gland and discard.



Remove rotary seal ring from sleeve and discard.



Remove drive from drive lugs in the sleeve and discard.




Remove the shaft O-Ring (V) from the sleeve and discard.


9.1.2 Seal Assembly



Tools required for assembly of seal: Hex key and two types of grease (supplied with seal); lint-free cloth, tweezers or a thin pick (supplied by customer); for installation of O-Rings and drive tube). Clean all metal components with an approved solvent, including all gasket and O-Ring surfaces. Place metal components and all spare seal components on a clean dry surface.



Pick up the drive tube (use tweezers if necessary) and install onto each of the lugs in the follower assembly. Ensure the drive tube are fully seated on the lugs.



Apply a thin film of **white** grease to the rotary O-Ring (W) and install into the groove on the outer diameter of the rotary face. Ensure cushions are on the back of the rotary face.




Align the mark on the rotary face with the notch on the sleeve. Slide the rotary face down to the sleeve and gently compress until it is seated. The sleeve drive lugs should engage the slots on the rotary face. **CAUTION: Do not compress drive tube.**




Clean the rotary face with an approved solvent and a lint-free cloth.




For seals with Bushing kit: Apply a thin film of **white** grease to the O-Ring (Y) and install into the groove on the bronze bushing. **IMPORTANT: Ensure the O-Ring is completely seated and fully captured within the O-Ring groove.** The O-Ring may appear to be oversize when installing and will need to be worked in.



For seals with Bushing kit: Install the bushing into the counter bore of the gland with the bushing O-Ring (Y) facing downward.




For seals with Bushing kit: Install the snap ring on top of the bushing and into the groove in the gland to secure the bushing into the gland.



For seals with Injector option: Invert the gland. Compress and overlap the ends of the injector, position the splits opposite the F (flush) port and install in the gland groove. **IMPORTANT: The injector should snap into place. Ensure the split ends do not overlap when fully installed; make adjustments until the ends meet.**


9.1.2 Seal Assembly cont.



Fill the four (or two, based on the seal size) evenly spaced holes, marked by dimples, with the **635 SXC grease** supplied with the seal. Wipe off excess grease. **Helpful Hint:** Use the follower plate as a guide to confirm that grease will be applied to the correct holes.




Dip the ends of the springs into white grease and insert into each spring hole. **IMPORTANT: DO NOT insert springs into the four (two) evenly spaced holes marked by dimples and previously filled with 635 SXC grease.**



Align the pins on the follower plate with the marked, **635 SXC grease** filled holes in the gland and press down the plate into the gland until the follower plate rests on the springs.




Apply a thin film of **white grease** to the stationary face O-Ring (X) and install into the groove in the gland above the follower plate assembly.



Ensure the stationary cushions are properly installed, with the overhanging section at the break-edges folded onto the sides of the slots.




Align the slots on the stationary face with the lugs on the follower plate and gently compress the stationary face down until it is fully seated. **CAUTION: Improper alignment will result in chipping at the slot edges of the face.** Clean the stationary face with a lint-free cloth and an approved cleaning solvent that complies with local and site regulations.



Install the $\frac{1}{4}$ dog set screws (1) into the screw holes marked with a dimple on the outside diameter of the lock ring. Install the cup point set screws (2) into the remaining holes in the lock ring. **IMPORTANT: The screws should not protrude into the inner diameter of the lock ring prior to installing onto the seal sleeve.**




Invert the sleeve assembly and insert it into the gland bore.




Lift up on the gland and hold the bottom of the sleeve to invert and gently set down to initiate contact between the stationary and rotary faces.

9.0 SEAL REBUILD cont.


9.1.2 Seal Assembly cont.




Place the lock ring on top of the sleeve and align the three vertical dimples on the outer diameter of the lock ring with the notch on the top edge of the sleeve.



Gently press down on the top of the lock ring and tighten the 1/4 dog set screws and then the cup point screws with the hex key supplied with the seal. **IMPORTANT: The set screws should be tightened just enough to ensure that they are secure but should not protrude into the inner diameter of the sleeve.**




Install the centering clips on the outer diameter of the lock ring with the centering clip flat head screws.




Press down on the top of the gland to compress the assembly and turn each centering clip to engage the groove on the top of the gland and hand-tight the centering clip flat head screw. Repeat this step for all centering clips. Retighten with a torque wrench:

Sizes 25 mm – 65 mm (1.000" – 2.625")
to 5,5 – 6,5 Nm (50 – 60 in-lbs.),
4,5 Nm (40 in-lbs.)

Sizes 70 mm – 120 mm (2.750" – 4.750")
to 12 – 13 Nm (105 – 115 in-lbs.),
7,8 Nm (70 in-lbs.).



Apply a thin film of **white** grease to the shaft O-Ring (V) and install on the sleeve inside diameter O-Ring groove. Peel off the adhesive backing from the gland gasket and install in the gland gasket recess.



The seal is ready for installation.

10.0 MECHANICAL SEAL RETURNS AND HAZARD COMMUNICATION REQUIREMENTS

Any mechanical seal returned to Chesterton that has been in operation, must comply with our Hazard Communication requirements. Please go to our web page at **chesterton.com/Mechanical_Seal>Returns** to obtain information required for returning seals for repair or seal analysis.



DISTRIBUTED BY:

Chesterton ISO certificates available on chesterton.com/corporate/iso

860 Salem Street
Groveland, MA 01834 USA
Telephone: +1 781-438-7000 Fax: 978-469-6528
chesterton.com

© 2024 A.W. Chesterton Company.
® Registered trademark owned by A.W. Chesterton Company
in USA and other countries.

FORM NO. EN393586 REV 3

12/24